

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and staff safety throughout the pandemic.

School District:	61 - Greater Victoria
School Name:	Gordon Head Middle
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2023-07-31
	Date of next inspection: 2023-10-31
	Date and type of most recent maintenance: 23-07-31 Check filters and belts, add oil ports if applicable
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail: We looked at ultraviolet germicidal exposure to UV-C which caused eye irritation. Ultraviolet germicidal exposure to UV-C can cause cancer. The virus is new and though researchers are attempting to find out if this technology works there is not enough evidence it kills the virus. We looked at Needlepoint Ionization and though it cleans the air there is no independent research that says it kills the virus. There is research that suggests the molecular structure of disrupted ions may creates harmful VOC, etc. We will not use this.
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: To the best of our ability. However when we need to our fresh air is running near 100%, windows open and recently, to assist with extraction many fans such as washroom fans may be running 24/7. We know this is an issue with our Energy Manager but trying to remove

Other Relevant Information:

possible air contamination is paramount.